



District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), Siddharth Nagar

Office of Executive Engineer, Construction division, U.P Jal Nigam, Infront of district hospital, Siddharth Nagar. Pin-272207 (Test Address only)

Test report

Sample ID: *U1232709512743536

User Information

Name: Sanjay Kumar Kanaujia Mobile: 7310091934

Email: sanjaybasti1994@gmail.com Pin Code:

Full Address: Village- Not available , Gram Panchayat- Not available, Block- Not available, District- Siddharth Nagar, State- Uttar Pradesh

Sample description

Source of Sample: PrivateTube well / Bore well / Well, location : Siddharth Public Village: Karauda Masina
Gram Panchayat: Karauda Masina Block: Jogia Khas
District: Siddharth Nagar State: Uttar Pradesh
Address: Remarks:
Latitude: Longitude:

Date & time of sample collection

07.06.2023 | 10:55:00 AM

Date & time of sample received in lab

07.06.2023 | 11:29:00 AM


Date & time of sample analysed

08.06.2023 | 11:33:00 AM

Date & time of report generation

08.06.2023 | 11:33:00 AM


PRINCIPAL
Siddharth Public School
Karauda Masina-Siddharth Nagar



प्रबन्धक
सिद्धार्थ पब्लिक स्कूल
सिद्धार्थनगर

Test Results

Sl. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Chloride (as Cl)	mg/l	250	1000	79.920	Safe
2	Conductivity	micromhos per centimeter / microsiemens per centimeter	NA	NA	854.500	Safe
3	E.coli	MPN/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	Safe
4	Free residual Chlorine	mg/l	0.2	1	0.040	Safe
5	Iron (As Fe)	mg/l	1	No Relaxation	0.010	Safe
6	Nitrate (as NO ₃)	mg/l	45	No Relaxation	20.000	Safe
7	pH	NA	6.5-8.5	No Relaxation	7.740	Safe
8	Sulphate (as SO ₄)	mg/l	200	400	86.000	Safe
9	TDS	mg/l	500	2000	410.500	Safe
10	Total Alkalinity (as Calcium Carbonate)	mg/l	200	600	20.000	Safe
11	Total Arsenic (As As)	mg/l	0.01	No Relaxation	0.000	Safe
12	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	Safe
13	Total Hardness (As CaCO ₃)	mg/l	200	600	144.000	Safe
14	Turbidity	NTU	1	5	0.980	Safe


Note:

- 1) *Indicates parameters that are NABL accredited.
- 2) This test results related to the sample tested above
- 3) The report shall not to be reproduced in full without approval of authority
- 4) This is the end of the report


 Authorised signatory
 Mahesh Prasad, Test Lab Incharge

Jeevan Mission aims at potable tap water supply to every home
 Let us join hands for drinking water is potable. It helps in preventing water borne diseases and improve public health.


PRINCIPAL
Siddharth Public School
 Karanda Masina-Siddharth Nagar


 Authorised signatory
 Mahesh Prasad, Test Lab Incharge

SAFE DRINKING WATER AND SANITARY CONDITON CERTIFICATE

Date - 31/6/2023

It is to certify that an inspection team headed by Dr. A.K. Agarwal (Name of officers with designation) from _____

(Name of Department Office) inspected the Siddharth Public School, Karaunda Masina Siddharthnagar, U.P. (Name & Address of the school) on 19.05.2023 and found that the Siddharth Public School (Name of School) has safe drinking water facilities for the students and member's of staff of the institution and maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of one year.

Signature with seal: _____

Name: _____


Designation: _____

अधीक्षक
सामुदायिक स्वास्थ्य केंद्र
सिद्धार्थनगर

To,

Siddharth Public School
Karaunda Masina
Siddharthnagar, U.P.


PRINCIPAL
Siddharth Public School
Karaunda Masina-Siddharth Nage


प्रबंधक
सिद्धार्थ पब्लिक स्कूल
करीबत सिद्धार्थनगर